

## MARICOPA COUNTY Department of Transportation

**MEMORANDUM** 

Date: January 6, 2016

**To:** MAG Specifications and Details Committee

**From:** Robert Herz, MCDOT Representative


Subject: Revision to Detail 251 RETURN TYPE DRIVEWAYS Case 16-03

PURPOSE: Adjust concrete thickness and concrete class for commercial and industrial


driveways to match requirements shown on Detail 250.


**REVISIONS:** Change concrete thickness from 6" to 9" for commercial and industrial driveways. Change concrete from Class B to Class A for commercial and industrial driveways. Clarify payment limits for curb & gutter and for the driveway.


**QUESTIONS:** Should the same changes be made to alley entrances Details 262 and 263? Should residential driveways be deleted from Detail 251?



2901 West Durango Street Phoenix, Arizona 85009 Phone: 602-506-4760 Fax: 602-506-5969







NOTES:

DETAIL NO.

263

CLASS 'B' CONCRETE CONSTRUCTION PER SECT. 725.
 EXPANSION JOINTS SHALL CONFORM TO SECT. 340.
 SUBGRADE PREPARATION PER SECTION 301.


MARICOPA STANDARD DETAIL

WING TYPE ALLEY ENTRANCE (WITH ROLL TYPE CURB AND GUTTER)

SECTION A-A

263

01-01-2002



SECTION VALLEY G

REVISED

01-01-2010

DETAIL NO.

240

SUBGRADE PREPARATION AS PER SECT. 301 ———

VALLEY GUTTER

CONCRETE PAD REQUIRED

MARIDOPA STANDARD DETAIL

DETAIL NO.

240